



WASTE WATER FORCE MAIN

- ① LCU APPROVED JOINT RESTRAINT FOR P.V.C. M.J. PIPE AND FITTINGS PLACED IN ACCORDANCE WITH JOINT RESTRAINT SCHEDULE. (SEE DETAIL G-10)
- ② CONFLICT PIPE
- ③ LCU APPROVED C-900 PVC DR 14
- ④ 18" MIN. UNLESS OTHERWISE APPROVED BY LCU
- ⑤ 45° MECHANICAL JOINT FITTING, TYPICAL
- ⑥ 10 GAUGE DOUBLE INSULATED COPPER WIRE (SEE LCU STANDARD DETAIL)

NOT TO SCALE

		LEE COUNTY UTILITIES ENGINEERING <small>1500 MONROE STREET FORT MYERS, FLORIDA 33901</small>	
TITLE:		WASTE WATER FM VERTICAL OFFSET WITH FITTINGS	
REVISION:		3/7/24	DETAIL NO: S-01.dwg