


# **NOTES:**

1. UNIONS REQUIRED
2. INITIAL AND ANNUAL DEVICE TESTING REQUIRED
3. FOR COMMERCIAL SITES

- ①. LCU APPROVED REDUCED PRESSURE BACKFLOW PREVENTION DEVICE (SEE APPROVED MATERIALS LIST)
- ②. FULL FLOW BRONZE BALL VALVE
- ③. UNION
- ④. ALL PIPING AND FITTINGS SHALL BE BRASS OR COPPER
- ⑤. 12" MIN. - 24" MAX. UNLESS OTHERWISE APPROVED BY LCU
- ⑥. FINISHED GRADE
- ⑦. METER BOX (LCU OWNED & MAINTAINED)
- ⑧. 2' MAXIMUM
- ⑨. END OF LCU MAINTENANCE AT METER

**NOT TO SCALE**

		<b>LEE COUNTY UTILITIES ENGINEERING</b> <small>1500 MONROE STREET FORT MYERS, FLORIDA 33901</small>	
<b>TITLE:</b>		<b>3/4" TO 2" CROSS CONTROL ASSEMBLY</b>	
<b>REVISION:</b>		<b>12/18/24</b>	
<b>DETAIL NO:</b>		<b>W-08.dwg</b>	