


PARKWAY AREA OR NO SIDEWALK

(PLAN VIEW)


- ①. F.H. TO BE LOCATED 2' MINIMUM FROM EDGE OF SIDEWALK
- ②. PROPERTY LINE RIGHT-OF-WAY OR LIMIT OF EASEMENT
- ③. BETWEEN 5'-0" MIN. AND 12'-0" MAX.

NOTES:

1. OBSTRUCTIONS SUCH AS UTILITY POLES, STREET SIGNS, IRRIGATION BOXES, FENCES, ETC. SHALL NOT BE PLACED BETWEEN CURB AND HYDRANT.
2. SOME LOCATIONS APPLY AT EITHER END OF CURB RETURNS.
3. DIMENSIONS SHOWN ON CONSTRUCTION DRAWINGS SUPERCEDE LOCATIONS SHOWN HERE.



NOT TO SCALE

		<p>LEE COUNTY UTILITIES ENGINEERING</p> <p>1500 MONROE STREET FORT MYERS, FLORIDA 33901</p>
<p>TITLE: FIRE HYDRANT LOCATIONS & CLEARANCE</p>		
<p>REVISION: 9/10/24</p>	<p>DETAIL NO: W-13.dwg</p>	